

DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD)

Report Number: DPCC/W/CETP/19-20/131)1566

21/1/20

1. Name & Address of Ind. / Unit WAZIRPUR CETP (24 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 05.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	2.7	5.5-9.0	5.8	5.5-9.0	8.46
2	TSS	276	250	56	100	15.1
3	COD	568	...	92	250	90.0
4	BOD (3 days at 27° C)	185	...	30	30	23.1
5	Ni	7.5	3	4.4	3	-
6	Cu	ND	3	ND	3	-
7	Zn	4.5	15	1.3	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	250	...	240	1000	-
11	SO ₄	99.4	...	45.2	1000	-
12	Cd	ND	1	ND	0.05	-
13	Oil & Grease	24.8	20	9.6	10	-
14	TDS	2450	...	2100	2100	-
15	Ammonical Nitrogen as N	42.1	50	28.1	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.2	...	1.8	2.0	-

All values are in mg/l except pH


... No Standards

ND- Not Detectable

Flow: 2.00 MLD


SR. SCIENTIST
Dr. NANDITA MOITRA
Scientist 'C'


for SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF SMA CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/132 | 1567

21/1/20

- Name & Address of Ind. / Unit SMA CETP (12 MLD)
- Sampling location Inlet and Outlet of CETP
- Date of Sampling 05.12.19
- Sample analyzed and results DPCC LAB
- Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLM S
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	7.2	5.5-9.0	7.45
2	TSS	416	250	60	100	39.13
3	COD	520	...	132	250	81.7
4	BOD (3 days at 27° C)	175	...	42	30	9.72
5	Ni	6.3	3	4.0	3	-
6	Cu	ND	3	ND	3	-
7	Zn	2.4	15	1.8	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	1120	...	860	1000	-
11	SO ₄	249.7	...	72.5	1000	-
12	Cd	0.16	1	ND	0.05	-
13	Oil & Grease	28.0	20	8.4	10	-
14	TDS	1800	...	1520	2100	-
15	Ammonical Nitrogen as N	94.7	50	28.9	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	3.6	...	2.0	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 1.5 MLD

Nandita
SR. SCIENTIST
Dr. NANDITA MOITRA
Scientist 'C'

Bhant
for SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF OKHLA CETP (24 MLD)

Report Number: DPCC/W/CETP/19-20/139 | 1568

21/1/20

1. Name & Address of Ind. / Unit OKHLA CETP (24 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 10.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.4	5.5-9.0	7.5
2	TSS	620	250	48	100	21.308
3	COD	960	...	96	250	132.32
4	BOD (3 days at 27° C)	370	...	30	30	25.641
5	Ni	4.3	3	2.4	3	-
6	Cu	ND	3	ND	3	-
7	Zn	5.4	15	0.59	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	1240	...	720	1000	-
11	SO ₄	128.4	...	72.3	1000	-
12	Cd	0.14	0.1	ND	0.05	-
13	Oil & Grease	44.0	20	5.6	10	-
14	TDS	1940	...	1750	2100	-
15	Ammonical Nitrogen as N	42.7	50	29.0	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	7.2	2.0	1.7	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow: 2.715 MLD

N. Moitra
SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

for *Bharti*
SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NARELA CETP (24 MLD)

Report Number: DPCC/W/CETP/19-20/138

11569

21/1/20

1. Name & Address of Ind. / Unit NARELA CETP (24 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 09.12.2019
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.2	5.5-9.0	7.4	5.5-9.0	8.03
2	TSS	168	250	42	100	186.8
3	COD	260	...	84	250	202.5
4	BOD (3 days at 27° C)	90	...	28	30	50.5
5	Ni	3.2	3	0.64	3	-
6	Cu	ND	3	ND	3	-
7	Zn	2.9	15	0.24	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	740	...	420	1000	-
11	SO ₄	44.6	...	24.9	1000	-
12	Cd	0.14	0.1	ND	0.05	-
13	Oil & Grease	16.0	20	4.8	10	-
14	TDS	1900	...	1270	2100	-
15	Ammonical Nitrogen as N	24.9	50	12.6	50	-
16	Fluoride		15		2	-
17	Sulphide	2.4	2.0	0.8	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 10.8 MLD

N. Moitra

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

for Shant
SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NARAYANA CETP (21.6 MLD)

Report Number: DPCC/W/CETP/19-20/133 | 1570

21/1/20

1. Name & Address of Ind. / Unit NARAYANA CETP (21.6 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 06.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	-	5.5-9.0	-	5.5-9.0	-
2	TSS	-	250	-	100	-
3	COD	-	...	-	250	-
4	BOD (3 days at 27° C)	-	...	-	30	-
5	Ni	-	3	-	3	-
6	Cu	-	3	-	3	-
7	Zn	-	15	-	5	-
8	Cr (Total)	-	2	-	2	-
9	Pb	-	1	-	0.1	-
10	Cl	-	...	-	1000	-
11	SO ₄	-	...	-	1000	-
12	Cd	-	1	-	0.05	-
13	Oil & Grease	-	20	-	10	-
14	TDS	-	...	-	2100	-
15	Ammonical Nitrogen as N	-	50	-	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	-	...	-	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Remarks : Plant was non- operational due to electrical fault.

N. Moitra
SR. SCIENTIST
Dr. NANDITA MOITRA
Scientist 'C'

Bhanti
for SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NANGLOI CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/135 | 1571

21/1/20

1. Name & Address of Ind. / Unit NANGLOI CETP (12 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 06.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.2	5.5-9.0	7.52
2	TSS	648	250	84	100	77.1
3	COD	960	...	212	250	73.8
4	BOD (3 days at 27° C)	480	...	68	30	21.8
5	Ni	3.3	3	1.45	3	-
6	Cu	ND	3	ND	3	-
7	Zn	1.68	15	0.55	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	1150	...	720	1000	-
11	SO ₄	120.7	...	72.5	1000	-
12	Cd	ND	1	ND	0.05	-
13	Oil & Grease	36.0	20	7.2	10	-
14	TDS	2100	...	1890	2100	-
15	Ammonical Nitrogen as N	34.7	50	27.0	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	6.7	...	1.9	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable


Flow: 2.71 MLD

Nandita

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

Bharti
for SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD)

Report Number: DPCC/W/CETP/19-20/134/157A

21/1/20

1. Name & Address of Ind. / Unit MANGOLPURI CETP (2.4 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 06.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.1	5.5-9.0	7.3	5.5-9.0	8.36
2	TSS	404	250	68	100	48.1
3	COD	760	...	148	250	83.0
4	BOD (3 days at 27° C)	280	...	48	30	27.6
5	Ni	3.48	3	2.29	3	-
6	Cu	ND	3	ND	3	-
7	Zn	1.48	15	0.66	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	1340	...	1170	1000	-
11	SO ₄	120.8	...	86.5	1000	-
12	Cd	ND	1	ND	0.05	-
13	Oil & Grease	32.0	20	5.6	10	-
14	TDS	2340	...	1920	2100	-
15	Ammonical Nitrogen as N	72.3	50	36.4	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	6.6	...	2.4	2.0	-

All values are in mg/l except pH

... No Standards


ND- Not Detectable

Flow :1.5 MLD

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

Bhanti
for SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/130 | 1573

21/1/20

1. Name & Address of Ind. / Unit LAWRENCE ROAD (12 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 05.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.2	5.5-9.0	7.04
2	TSS	356	250	146	100	61.03
3	COD	480	...	216	250	86.62
4	BOD (3 days at 27° C)	172	...	72	30	23.07
5	Ni	4.39	3	1.35	3	-
6	Cu	ND	3	ND	3	-
7	Zn	2.29	15	0.98	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	2100	...	1740	1000	-
11	SO ₄	218.0	...	94.3	1000	-
12	Cd	ND	1	ND	0.05	-
13	Oil & Grease	32.0	20	10.4	10	-
14	TDS	2560	...	1920	2100	-
15	Ammonical Nitrogen as N	44.7	50	33.0	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	7.2	...	2.4	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow:1 MLD


N. Mitra

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist

Bhathi

SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD)

Report Number: DPCC/W/CETP/19-20/127 /1574

21/1/20

1. Name & Address of Ind. / Unit JHILMIL CETP (16.8 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 02.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	7.3	5.5-9.0	-
2	TSS	560	250	58	100	-
3	COD	368	...	236	250	-
4	BOD (3 days at 27° C)	120	...	32	30	-
5	Ni	3.64	3	3.09	3	-
6	Cu	ND	3	ND	3	-
7	Zn	2.98	15	1.09	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	1235	...	950	1000	-
11	SO ₄	560.7	...	120.5	1000	-
12	Cd	0.39	1	ND	0.05	-
13	Oil & Grease	40.8	20	4.4	10	-
14	TDS	2820	...	1730	2100	-
15	Ammonical Nitrogen as N	94.6	50	21.2	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	7.8	...	1.2	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 16.8 MLD

Remarks: OLMS was not working at the time of DPCC monitoring.

Maitra

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

for *Shanti*
SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF BAWANA CETP (35 MLD)

Report Number: DPCC/W/CETP/19-20/137

1575

21/1/20

1. Name & Address of Ind. / Unit BAWANA CETP (35 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 09.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.2	5.5-9.0	6.8	5.5-9.0	7.26
2	TSS	680	250	46	100	37.00
3	COD	860	...	120	250	84.25
4	BOD (3 days at 27° C)	410	...	28	30	27.44
5	Ni	7.39	3	1.48	3	-
6	Cu	ND	3	ND	3	-
7	Zn	3.89	15	1.99	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	720	...	570	1000	-
11	SO ₄	120.9	...	57.3	1000	-
12	Cd	0.22	0.1	ND	0.05	-
13	Oil & Grease	36.8	20	3.2	10	-
14	TDS	2480	...	1740	2100	-
15	Ammonical Nitrogen as N	68.8	50	19.2	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	3.4	2.0	1.0	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 19 MLD

Nandita

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

for Bhanu
SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF BADLI CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/128 11576

21/1/20

1. Name & Address of Ind. / Unit BADLI CETP (12 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 04.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.4	5.5-9.0	6.8	5.5-9.0	8.58
2	TSS	180	250	64	100	21.0
3	COD	240	...	168	250	89.2
4	BOD (3 days at 27° C)	80	...	56	30	14.3
5	Ni	1.98	3	0.85	3	-
6	Cu	ND	3	ND	3	-
7	Zn	2.96	15	1.92	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	720	...	440	1000	-
11	SO ₄	105.6	...	58.6	1000	-
12	Cd	0.24	1	ND	0.05	-
13	Oil & Grease	28.0	20	5.6	10	-
14	TDS	1240	...	980	2100	-
15	Ammonical Nitrogen as N	48.5	50	30.7	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.8	...	1.7	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow: 1.92 MLD

N. Mehta

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

P. Bhatt
SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF GTK CETP (6 MLD)

Report Number: DPCC/W/CETP/19-20/129) 15 >>

21/1/20

1. Name & Address of Ind. / Unit GTK CETP (6 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 05.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.5	5.5-9.0	7.4
2	TSS	740	250	80	100	43.81
3	COD	800	...	130	250	121.96
4	BOD (3 days at 27° C)	280	...	48	30	25.47
5	Ni	4.14	3	2.40	3	-
6	Cu	ND	3	ND	3	-
7	Zn	2.93	15	1.11	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	960	...	720	1000	-
11	SO ₄	480.4	...	92.4	1000	-
12	Cd	1.1	1	ND	0.05	-
13	Oil & Grease	48.0	20	8.4	10	-
14	TDS	1440	...	1120	2100	-
15	Ammonical Nitrogen as N	26.8	50	20.6	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	6.4	...	1.0	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 2.5 MLD


Nandita

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

Bharti

SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF MAYAPURI CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/136

1. Name & Address of Ind. / Unit MAYAPURI CETP (12 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 06.12.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.5	5.5-9.0	7.40
2	TSS	396	250	52	100	21.4
3	COD	720	...	92	250	58.1
4	BOD (3 days at 27° C)	240	...	30	30	15
5	Ni	1.38	3	0.99	3	-
6	Cu	ND	3	ND	3	-
7	Zn	1.38	15	0.29	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	1390	...	920	1000	-
11	SO ₄	119.7	...	71.3	1000	-
12	Cd	0.11	1	ND	0.05	-
13	Oil & Grease	28.4	20	5.6	10	-
14	TDS	1670	...	1150	2100	-
15	Ammonical Nitrogen as N	92.7	50	35.0	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.3	...	2.0	2.0	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 2.25 MLD

N. Mitra
SR. SCIENTIST
Dr. NANDITA MOITRA
Scientist 'C'

Bhathi
for SCIENTIFIC ASSISTANT