

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF MAYAPURI CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/65 / 644

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MAYAPURI CETP (12 MLD)
Inlet and Outlet of CETP
22.07.19
DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	8.0	5.5-9.0	6.68
2	TSS	280	250	58	100	58.8
3	COD	320	...	86	250	87.5
4	BOD (3 days at 27° C)	108	...	24	30	31.1
5	Ni	ND	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.45	15	0.27	5	-
8	Cr (Total)	0.16	2	0.12	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	840	...	530	1000	-
11	SO ₄	196.8	...	125.6	1000	-
12	Cd	1.68	1	1.41	1	-
13	Oil & Grease	18.6	20	2.4	10	-
14	TDS	1750	...	1240	2100	-
15	Ammonical Nitrogen as N	42.5	50	29.3	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	2.8	...	1.4	2.8	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 12 MLD

Mishra
SR. SCIENTIST

[Signature]
SCIENTIFIC ASSISTANT

le



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF BAWANA CETP (35 MLD)

Report Number: DPCC/W/CETP/19-20/64/643

Date 14/08/2019

- | | |
|-----------------------------------|--------------------------|
| 1. Name & Address of Ind. / Unit | BAWANA CETP (35 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 18.07.19 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.2	5.5-9.0	7.13
2	TSS	416	250	74	100	81.78
3	COD	488	...	96	250	114.29
4	BOD (3 days at 27° C)	160	...	28	30	20.46
5	Ni	ND	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.41	15	0.21	5	-
8	Cr (Total)	0.23	2	0.18	2	-
9	Pb	0.24	1	ND	0.1	-
10	Cl	1880	...	1650	1000	-
11	SO ₄	198.5	...	78.5	1000	-
12	Cd	1.49	1	1.25	1	-
13	Oil & Grease	24.8	20	3.2	10	-
14	TDS	2552	...	2400	2100	-
15	Ammonical Nitrogen as N	72.5	50	42.9	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	7.2	...	2.4	2.8	-


All values are in mg/l except pH

... No Standards
 ND- Not Detectable
 Flow : 14.0 MLD

Mitra
 SR. SCIENTIST

[Signature]
 SCIENTIFIC ASSISTANT

1.2
 1.1
 NI
 6
 78
 3
 4
 12



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NARELA CETP (24 MLD)

Report Number: DPCC/W/CETP/19-20/63 / 612

Date 14/08/2018

- | | |
|-----------------------------------|--------------------------|
| 1. Name & Address of Ind. / Unit | NARELA CETP (24 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 18.07.19 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.2	5.5-9.0	7.9	5.5-9.0	7.71
2	TSS	616	250	62	100	20.9
3	COD	344	...	84	250	50.4
4	BOD (3 days at 27° C)	120	...	26	30	13.1
5	Ni	4.48	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	1.24	15	0.38	5	-
8	Cr (Total)	0.13	2	0.10	2	-
9	Pb	0.35	1	0.29	0.1	-
10	Cl	1260	...	1150	1000	-
11	SO ₄	410.2	...	148.6	1000	-
12	Cd	1.25	1	0.97	1	-
13	Oil & Grease	12.4	20	3.2	10	-
14	TDS	2740	...	2640	2100	-
15	Ammonical Nitrogen as N	78.9	50	34.5	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.4	...	1.2	2.8	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 7.2 MLD

N. Mishra
SR. SCIENTIST

9
2
4
5
10
10
18
10
10
50
16
17
2
40
3.5

SCIENTIFIC ASSISTANT



ANALYSIS REPORT OF OKHLA CETP (24 MLD)

Report Number: DPCC/W/CETP/19-20/62 /641


Date 14/08/2019

- | | |
|-----------------------------------|--------------------------|
| 1. Name & Address of Ind. / Unit | OKHLA CETP (24 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 11.07.19 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.3	5.5-9.0	7.14
2	TSS	728	250	68	100	64.3
3	COD	324	...	116	250	129.59
4	BOD (3 days at 27° C)	96	...	38	30	21.68
5	Ni	0.44	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.70	15	0.17	5	-
8	Cr (Total)	0.25	2	0.18	2	-
9	Pb	0.29	1	ND	0.1	-
10	Cl	660	...	545	1000	-
11	SO ₄	204.6	...	125.2	1000	-
12	Cd	1.53	1	1.09	1	-
13	Oil & Grease	18.4	20	4.2	10	-
14	TDS	1520	...	1520	2100	-
15	Ammonical Nitrogen as N	68.2	50	44.5	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.2	...	1.7	2.8	-

All values are in mg/l except pH

... No Standards
ND- Not Detectable
Flow: 2.58 MLD


SR. SCIENTIST


SCIENTIFIC ASSISTANT

2



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD)

Report Number: DPCC/W/CETP/19-20/61/640

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MANGOLPURI CETP (2.4 MLD)
 Inlet and Outlet of CETP
 10.07.19
 DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.9	5.5-9.0	7.47
2	TSS	428	250	62	100	2.2
3	COD	976	...	76	250	17.8
4	BOD (3 days at 27° C)	330	...	24	30	3.5
5	Ni	6.78	3	1.01	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.79	15	0.32	5	-
8	Cr (Total)	1.13	2	0.29	2	-
9	Pb	0.02	1	ND	0.1	-
10	Cl	3085	...	2985	1000	-
11	SO ₄	101.2	...	92.4	1000	-
12	Cd	1.17	1	0.85	1	-
13	Oil & Grease	20.8	20	2.4	10	-
14	TDS	2710	...	2520	2100	-
15	Ammonical Nitrogen as N	48.7	50	29.5	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.8	...	3.2	2.8	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 1.98 MLD

Mishra
SR. SCIENTIST

[Signature]
SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NANGLOI CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/60/639

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

NANGLOI CETP (12 MLD)
 Inlet and Outlet of CETP
 10.07.19
 DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standard	Water Quality	EPA Standards	
1	pH	8.1	5.5-9.0	7.7	5.5-9.0	7.20
2	TSS	576	250	82	100	39.2
3	COD	676	...	112	250	65.9
4	BOD (3 days at 27° C)	200	...	32	30	12.5
5	Ni	0.25	3	ND	3	-
6	Cu	4.76	3	ND	3	-
7	Zn	0.32	15	0.40	5	-
8	Cr (Total)	0.29	2	0.24	2	-
9	Pb	0.13	1	ND	0.1	-
10	Cl	2870	...	2687	1000	-
11	SO ₄	435.8	...	117.5	1000	-
12	Cd	1.29	1	1.01	1	-
13	Oil & Grease	12.4	20	2.4	10	-
14	TDS	2740	...	2710	2100	-
15	Ammonical Nitrogen as N	72.8	50	24.8	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	3.2	...	1.2 ⁰¹	2.8	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow: 2.94 MLD

Mishra
SR. SCIENTIST

[Signature]
SCIENTIFIC ASSISTANT

[Handwritten mark]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF BADLI CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/59/638

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

BADLI CETP (12 MLD)
 Inlet and Outlet of CETP
 10.07.19
 DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.1	5.5-9.0	6.2	5.5-9.0	7.72
2	TSS	268	250	58	100	17.2
3	COD	256	...	136	250	61.1
4	BOD (3 days at 27° C)	96	...	40	30	8.4
5	Ni	ND	3	ND	3	-
6	Cu	1.98	3	ND	3	-
7	Zn	2.19	15	0.53	5	-
8	Cr (Total)	0.44	2	0.18	2	-
9	Pb	0.18	1	0.02	0.1	-
10	Cl	580	...	420	1000	-
11	SO ₄	915	...	784.5	1000	-
12	Cd	0.97	1	0.93	1	-
13	Oil & Grease	28.4	20	3.6	10	-
14	TDS	1390	...	1270	2100	-
15	Ammonical Nitrogen as N	42.5	50	24.5	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	6.4	...	2.4	2.8	-

All values are in mg/l except pH

... No Standards


ND- Not Detectable

Flow : 2.01 MLD

N. Misha
SR. SCIENTIST

[Signature]
SCIENTIFIC ASSISTANT

4



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NARAYANA CETP (21.6 MLD)

Report Number: DPCC/W/CETP/19-20/58/637

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

NARAYANA CETP (21.6 MLD)
Inlet and Outlet of CETP
10.07.19
DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	8.1	5.5-9.0	7.7	5.5-9.0	6.86
2	TSS	436	250	36	100	72.1
3	COD	124	...	80	250	52.6
4	BOD (3 days at 27° C)	60	...	24	30	9.5
5	Ni	0.53	3	ND	3	-
6	Cu	0.30	3	0.19	3	-
7	Zn	0.38	15	0.19	5	-
8	Cr (Total)	0.28	2	0.16	2	-
9	Pb	0.13	1	ND	0.1	-
10	Cl	385	...	335	1000	-
11	SO ₄	898	...	709.8	1000	-
12	Cd	0.81	1	0.73	1	-
13	Oil & Grease	12.4	20	2.8	10	-
14	TDS	895	...	719	2100	-
15	Ammonical Nitrogen as N	50.54	50	12.75	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.9	...	2.9	2.8	-

All values are in mg/l except pH

... No Standards


ND- Not Detectable

Flow : 5.1 MLD

Mishra
SR. SCIENTIST

[Signature]
SCIENTIFIC ASSISTANT

[Handwritten mark]

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6visit us at : <http://dpcc.delhigovt.nic.in>**ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD)**

Report Number: DPCC/W/CETP/19-20/57/636

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

WAZIRPUR CETP (24 MLD)
Inlet and Outlet of CETP
09.07.19
DPCC LAB


S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	3.5	5.5-9.0	6.1	5.5-9.0	6.38
2	TSS	132	250	78	100	18
3	COD	316	...	96	250	53.9
4	BOD (3 days at 27° C)	110	...	24	30	9.8
5	Ni	1.59	3	0.25	3	-
6	Cu	2.36	3	ND	3	-
7	Zn	2.06	15	0.45	5	-
8	Cr (Total)	0.40	2	0.18	2	-
9	Pb	0.40	1	0.07	0.1	-
10	Cl	960	...	475	1000	-
11	SO ₄	119.6	...	117.8	1000	-
12	Cd	0.81	1	0.69	1	-
13	Oil & Grease	20.4	20	2.4	10	-
14	TDS	2090	...	2020	2100	-
15	Ammonical Nitrogen as N	54.5	50	39.5	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.0	...	2.1	2.8	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 2.61 MLD


SR. SCIENTIST
SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF GTK CETP (6 MLD)

Report Number: DPCC/W/CETP/19-20/56 / 635

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

GTK CETP (6 MLD)
Inlet and Outlet of CETP
09.07.19
DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standard s	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	7.5	5.5-9.0	7.04
2	TSS	116	250	22	100	46.14
3	COD	276	...	64	250	137.65
4	BOD (3 days at 27° C)	80	...	20	30	18.70
5	Ni	1.78	3	0.827	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.48	15	0.44	5	-
8	Cr (Total)	0.33	2	0.40	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	660	...	250	1000	-
11	SO ₄	513	...	423.8	1000	-
12	Cd	0.53	1	0.53	1	-
13	Oil & Grease	24.8	20	3.6	10	-
14	TDS	1570	...	1130	2100	-
15	Ammonical Nitrogen as N	39.8	50	24.5	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	2.7	...	1.9	2.8	-

All values are in mg/l except pH

... No Standards


ND- Not Detectable

Flow : 2.7 MLD

Maitra
SR. SCIENTIST

[Signature]
SCIENTIFIC ASSISTANT

2



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T of Delhi)
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/55/634

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

LAWRENCE ROAD (12 MLD)
NO FLOW
09.07.19
DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	6.9	5.5-9.0	7.24
2	TSS	132	250	78	100	29.13
3	COD	496	...	180	250	140.15
4	BOD (3 days at 27° C)	120	...	56	30	24.34
5	Ni	0.63	3	0.25	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.34	15	0.22	5	-
8	Cr (Total)	0.55	2	0.20	2	-
9	Pb	0.79	1	0.13	0.1	-
10	Cl	1400	...	1335	1000	-
11	SO ₄	132.8	...	100.6	1000	-
12	Cd	0.89	1	0.81	1	-
13	Oil & Grease	24.8	20	6.4	10	-
14	TDS	2170	...	2090	2100	-
15	Ammonical Nitrogen as N	59.85	50	24.59	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	5.8	...	2.4	2.8	-

All values are in mg/l except pH

... No Standards
ND- Not Detectable
Flow: 1.2 MLD

Mishra
SR. SCIENTIST

[Signature]
SCIENTIFIC ASSISTANT

[Handwritten mark]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD)

Report Number: DPCC/W/CETP/19-20/54 / 633

Date 14/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

JHILMIL CETP (16.8 MLD)

Inlet and Outlet of CETP

08.07.19

DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.9	5.5-9.0	8.0	5.5-9.0	8.30
2	TSS	168	250	68	100	ERROR
3	COD	264	...	144	250	ERROR
4	BOD (3 days at 27° C)	80	...	46	30	ERROR
5	Ni	1.01	3	0.44	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.37	15	0.27	5	-
8	Cr (Total)	0.45	2	0.31	2	-
9	Pb	1.28	1	0.95	0.1	-
10	Cl	860	...	765	1000	-
11	SO ₄	760.6	...	105.6	1000	-
12	Cd	0.77	1	0.45	1	-
13	Oil & Grease	16.4	20	3.6	10	-
14	TDS	1620	...	1600	2100	-
15	Ammonical Nitrogen as N	24.4	50	12.7	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.8	...	2.1	2.8	-

All values are in mg/l except pH

... No Standards


ND- Not Detectable

Flow : 5.19 MLD

N. Mitha
SR. SCIENTIST

[Signature]
SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE
 (Government of N.C.T of Delhi)
 4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
 visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF SMA CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/53 / 632

Date 19/08/2019

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

SMA CETP (12 MLD)
 Inlet and Outlet of CETP
 08.07.19
 DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.9	5.5-9.0	7.6	5.5-9.0	7.27
2	TSS	124	250	62	100	25.92
3	COD	200	...	96	250	109.71
4	BOD (3 days at 27° C)	60	...	27	30	14.81
5	Ni	4.09	3	ND	3	-
6	Cu	2.55	3	ND	3	-
7	Zn	0.45	15	0.36	5	-
8	Cr (Total)	0.51	2	0.41	2	-
9	Pb	1.01	1	0.40	0.1	-
10	Cl	1110	...	960	1000	-
11	SO ₄	697	...	530	1000	-
12	Cd	0.53	1	0.41	1	-
13	Oil & Grease	20.4	20	2.4	10	-
14	TDS	2130	...	205	2100	-
15	Ammonical Nitrogen as N	52.84	50	20.80	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	2.7	...	1.7	2.8	-

All values are in mg/l except pH

... No Standards
 ND- Not Detectable
 Flow : 2.60 MLD

V. Mittal
 SR. SCIENTIST

[Signature]
 SCIENTIFIC ASSISTANT

[Handwritten mark]