

AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
 SMA (12 MLD)  
 29/05/2020  
 10:40 to 10:50  
 Mr. Prabhat Jha  
 5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	2.88	5.5-9.0	7.64	5.5-9.0	7.18
2	TSS	138.0	250	24.0	100	36.929
3	COD	248.0	-	44.0	250	30.713
4	BOD (3 Days at 27°C)	80.0	-	12.0	30	10.838
5	Ni	2.954	3	0.070	3	-
6	Cu	3.097	3	BLQ(LOQ-0.01)	3	-
7	Zn	2.120	15	BLQ(LOQ-0.2)	5	-
8	Cr (Total)	6.951	2	BLQ(LOQ-0.002)	2	-
9	Pb	0.032	1	BLQ(LOQ-0.01)	0.1	-
10	Cl	710.0	-	780.0	1000	-
11	SO <sub>4</sub>	1180.0	-	986.0	1000	-
12	Cd	0.003	1	BLQ(LOQ-0.002)	0.05	-
13	Oil & Grease	18.6	20	BDL (DL-3.0)	10	-
14	TDS	3080.0	-	2540.0	2100	-
15	Ammonical Nitrogen as N	180.0	50	16.0	50	-
16	Fluoride	1.8	15	0.2	2	-
17	Sulphide	4.4	-	2.8	2.0	-

All values are in mg/l except pH  
 pH (at Site), TDS (at Site)  
 Flow : 1.6 MLD

*N. Mitra*  
 Dr. NANDITA MOITRA  
 Scientist 'C'

**AVON FOOD LAB PVT. LTD.**

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
 Wazirpur (24 MGD)  
 21/05/2020  
 11:20 to 11:30  
 Mr. Navneet Srivastava  
 5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.79	5.5-9.0	6.87	5.5-9.0	6.79
2	TSS	226.0	250	24.8	100	33.3
3	COD	272.0	-	52.0	250	89.6
4	BOD (3 Days at 27°C)	72.0	-	16.0	30	17.5
5	Ni	0.0030	3	0.0247	3	-
6	Cu	BLQ (LOQ-0.01)	3	BLQ (LOQ-0.01)	3	-
7	Zn	BLQ (LOQ-0.002)	15	BLQ (LOQ-0.002)	5	-
8	Cr (Total)	BLQ (LOQ-0.002)	2	BLQ (LOQ-0.002)	2	-
9	Pb	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.1	-
10	Cl	310.0	-	340.0	1000	-
11	SO <sub>4</sub>	616.0	-	670.0	1000	-
12	Cd	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.05	-
13	Oil & Grease	19.8	20	BDL (DL-4.0)	10	-
14	TDS	1350.0	-	1550.0	2100	-
15	Ammonical Nitrogen as N	88.0	50	24.4	50	-
16	Fluoride	2.8	15	0.4	2	-
17	Sulphide	4.4	-	1.6	2.0	-

All values are in mg/l except pH  
 pH (at Site), TDS (at Site)  
 Flow : 2.02 MLD

*N. Moitra*  
 Dr. NANDITA MOITRA  
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
Lawrence Road (12 MLD)  
01/06/2020  
14:10 to 14:20  
Mr. Suneshwar Singh  
5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.21	5.5-9.0	7.58	5.5-9.0	-
2	TSS	368.0	250	126.0	100	20.222
3	COD	408.0	-	176.0	250	54.158
4	BOD (3 Days at 27°C)	140.0	-	56.0	30	17.828
5	Ni	BLQ(LOQ-0.01)	3	BLQ(LOQ-0.01)	3	-
6	Cu	BLQ(LOQ-0.01)	3	BLQ(LOQ-0.01)	3	-
7	Zn	BLQ(LOQ-0.2)	15	BLQ(LOQ-0.2)	5	-
8	Cr (Total)	BLQ(LOQ-0.01)	2	BLQ(LOQ-0.01)	2	-
9	Pb	BLQ(LOQ-0.01)	1	BLQ(LOQ-0.01)	0.1	-
10	Cl	890.0	-	930.0	1000	-
11	SO <sub>4</sub>	1240.0	-	1090.0	1000	-
12	Cd	BLQ(LOQ-0.002)	1	BLQ(LOQ-0.002)	0.05	-
13	Oil & Grease	24.8	20	6.8	10	-
14	TDS	2454.0	-	2502.0	2100	-
15	Ammonical Nitrogen as N	196.0	50	21.8	50	-
16	Fluoride	2.1	15	0.3	2	-
17	Sulphide	5.6	-	1.8	2.0	-

All values are in mg/l except pH  
pH (at Site), TDS (at Site)  
Flow : 1.20 MLD

*N. Moitra*  
Dr. NANDITA MOITRA  
Scientist 'C'

AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
 Jhilmil (16.8 MLD)  
 27/05/2020  
 11:20 to 11:30  
 Mr. Suneshwar Singh  
 5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.44	5.5-9.0	7.85	5.5-9.0	7.74
2	TSS	126.0	250	18.8	100	24.1
3	COD	288.0	-	40.0	250	53.3
4	BOD (3 Days at 27°C)	100.0	-	14.0	30	23.4
5	Ni	0.758	3	0.161	3	-
6	Cu	0.245	3	0.022	3	-
7	Zn	BLQ(LOQ-0.2)	15	BLQ(LOQ-0.2)	5	-
8	Cr (Total)	0.845	2	0.0402	2	-
9	Pb	BLQ(LOQ-0.01)	1	BLQ(LOQ-0.01)	0.1	-
10	Cl	280.0	-	320.0	1000	-
11	SO <sub>4</sub>	670.0	-	760.0	1000	-
12	Cd	BLQ(LOQ-0.002)	1	BLQ(LOQ-0.002)	0.05	-
13	Oil & Grease	22.6	20	BDL (DL-3.0)	10	-
14	TDS	1060.0	-	1796.0	2100	-
15	Ammonical Nitrogen as N	96.0	50	32.0	50	-
16	Fluoride	1.2	15	0.3	2	-
17	Sulphide	5.6	-	2.8	2.0	-

All values are in mg/l except pH  
 pH (at Site), TDS  
 (at Site)  
 Flow : 5.19 MLD

*N. Mitra*  
 Dr. NANDITA MOITRA  
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
 Mayapuri (12 MLD)  
 21/05/2020  
 13:00 to 13:10  
 Mr. Navneet Srivastava  
 5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.48	5.5-9.0	7.68	5.5-9.0	8.46
2	TSS	312.0	250	52.0	100	39.9
3	COD	512.0	-	100.0	250	40.8
4	BOD (3 Days at 27°C)	180.0	-	30.0	30	12.4
5	Ni	0.0081	3	0.0700	3	-
6	Cu	BLQ (LOQ-0.01)	3	BLQ (LOQ-0.01)	3	-
7	Zn	BLQ (LOQ-0.002)	15	BLQ (LOQ-0.002)	5	-
8	Cr (Total)	BLQ (LOQ-0.002)	2	BLQ (LOQ-0.002)	2	-
9	Pb	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.1	-
10	Cl	360.0	-	390.0	1000	-
11	SO <sub>4</sub>	294.0	-	250.0	1000	-
12	Cd	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.05	-
13	Oil & Grease	22.8	20	4.8	10	-
14	TDS	1080.0	-	1220.0	2100	-
15	Ammonical Nitrogen as N	110.0	50	28.0	50	-
16	Fluoride	2.8	15	0.3	2	-
17	Sulphide	4.0	-	1.6	2.0	-

All values are in mg/l except pH  
 pH (at Site), TDS  
 (at Site)  
 Flow : 1.75 MLD

*Nandita*  
 Dr. NANDITA MOITRA  
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
 Naraina (21 MLD)  
 21/05/2020  
 12:15 to 12:25  
 Mr. Navneet Srivastava  
 5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.12	5.5-9.0	7.47	5.5-9.0	7.19
2	TSS	270.0	250	20.2	100	18.3
3	COD	480.0	-	44.0	250	89.2
4	BOD (3 Days at 27°C)	160.0	-	14.0	30	18.4
5	Ni	0.0537	3	0.0040	3	-
6	Cu	BLQ (LOQ-0.01)	3	BLQ (LOQ-0.01)	3	-
7	Zn	0.1070	15	BLQ (LOQ-0.002)	5	-
8	Cr (Total)	BLQ (LOQ-0.002)	2	BLQ (LOQ-0.002)	2	-
9	Pb	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.1	-
10	Cl	260.0	-	280.0	1000	-
11	SO <sub>4</sub>	188.0	-	196.0	1000	-
12	Cd	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.05	-
13	Oil & Grease	30.2	20	BDL (DL-4.0)	10	-
14	TDS	761.0	-	938.0	2100	-
15	Ammonical Nitrogen as N	180.0	50	28.8	50	-
16	Fluoride	2.8	15	0.2	2	-
17	Sulphide	3.8	-	1.8	2.0	-

All values are in mg/l except pH  
 pH (at Site), TDS (at Site)  
 Flow : 5.2 MLD

*N. Mitta*

Dr. NANDITA MOITRA  
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

1 Name & Address of Ind./Unit	Delhi Pollution Control Committee
2 Name of CETP Plant	Mangolpuri (2.4 MLD)
3 Date of Sampling	19/05/2020
4 Time of Sampling	13:30 to 13:40
5 Sampling Done by	Mr. Navneet Srivastava
6 Sample Quantity	5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.07	5.5-9.0	7.29	5.5-9.0	8.32
2	TSS	352.0	250	96.0	100	118.1
3	COD	824.0	-	104.0	250	472.6
4	BOD (3 Days at 27°C)	270.0	-	34.0	30	151.9
5	Ni	0.0171	3	0.1879	3	-
6	Cu	BLQ (LOQ-0.01)	3	BLQ (LOQ-0.01)	3	-
7	Zn	BLQ (LOQ-0.002)	15	0.1290	5	-
8	Cr (Total)	BLQ (LOQ-0.002)	2	BLQ (LOQ-0.002)	2	-
9	Pb	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.1	-
10	Cl	1624.5	-	684.8	1000	-
11	SO <sub>4</sub>	1140.0	-	986.0	1000	-
12	Cd	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.05	-
13	Oil & Grease	24.8	20	5.6	10	-
14	TDS	2956.0	-	1842.0	2100	-
15	Ammonical Nitrogen as N	210.0	50	34.2	50	-
16	Fluoride	3.2	15	0.4	2	-
17	Sulphide	4.2	-	3.4	2.0	-

All values are in mg/l except pH  
 pH (at Site), TDS (at Site)  
 Flow : 1.96 MLD

*N. Moitra*  
 Dr. NANDITA MOITRA  
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

1 Name & Address of Ind./Unit	Delhi Pollution Control Committee
2 Name of CETP Plant	Bawana (35 MLD)
3 Date of Sampling	19/05/2020
4 Time of Sampling	11:40 to 11:50
5 Sampling Done by	Mr. Navneet Srivastava
6 Sample Quantity	5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.15	5.5-9.0	7.71	5.5-9.0	7.12
2	TSS	226.0	250	22.8	100	33.21
3	COD	680.0	-	104.0	250	143.47
4	BOD (3 Days at 27°C)	230.0	-	32.0	30	19.35
5	Ni	BLQ (LOQ-0.002)	3	0.0501	3	-
6	Cu	BLQ (LOQ-0.01)	3	BLQ (LOQ-0.01)	3	-
7	Zn	BLQ (LOQ-0.002)	15	BLQ (LOQ-0.002)	5	-
8	Cr (Total)	BLQ (LOQ-0.002)	2	BLQ (LOQ-0.002)	2	-
9	Pb	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.1	-
10	Cl	1090.0	-	980.0	1000	-
11	SO <sub>4</sub>	1226.0	-	686.0	1000	-
12	Cd	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.05	-
13	Oil & Grease	26.8	20	6.4	10	-
14	TDS	4150.0	-	4090.0	2100	-
15	Ammonical Nitrogen as N	180.0	50	22.4	50	-
16	Fluoride	2.5	15	0.3	2	-
17	Sulphide	5.6	-	2.2	2.0	-

All values are in mg/l except pH  
 pH (at Site), TDS (at Site)  
 Flow : 24.6 MLD

*Nandita*  
 Dr. NANDITA MOITRA  
 Scientist 'C'



AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
Narela (22.5 MLD)  
15/05/2020  
14:40 to 15:00  
Mr. Navneet Srivastava  
5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.71	5.5-9.0	7.73	5.5-9.0	8.37
2	TSS	322.0	250	12.6	100	16.8
3	COD	1088.0	-	40.0	250	52.6
4	BOD (3 Days at 27°C)	360.0	-	12.0	30	10.1
5	Ni	BLQ (LOQ-0.002)	3	0.0467	3	-
6	Cu	BLQ (LOQ-0.01)	3	BLQ (LOQ-0.01)	3	-
7	Zn	BLQ (LOQ-0.002)	15	0.0048	5	-
8	Cr (Total)	BLQ (LOQ-0.002)	2	BLQ (LOQ-0.002)	2	-
9	Pb	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.1	-
10	Cl	980.0	-	810.0	1000	-
11	SO <sub>4</sub>	1320.0	-	1130.0	1000	-
12	Cd	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.05	-
13	Oil & Grease	25.6	20	BDL (DL-4.0)	10	-
14	TDS	3244.0	-	2864.0	2100	-
15	Ammonical Nitrogen as N	180.0	50	26.9	50	-
16	Fluoride	3.2	15	0.4	2	-
17	Sulphide	6.4	-	1.8	2.0	-

All values are in mg/l except pH  
pH (at Site), TDS (at Site)  
Flow : 10.81 MLD

*N. Mitra*  
Dr. NANDITA MOITRA  
Scientist 'C'

**AVON FOOD LAB PVT. LTD.**


1 Name & Address of Ind./Unit	Delhi Pollution Control Committee
2 Name of CETP Plant	G.T.K (6 MLD)
3 Date of Sampling	15/05/2020
4 Time of Sampling	11:00 to 11:10
5 Sampling Done by	Mr. Navneet Srivastava
6 Sample Quantity	5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.23	5.5-9.0	7.64	5.5-9.0	7.62
2	TSS	212.0	250	20.6	100	32.81
3	COD	272.0	-	64.0	250	132.54
4	BOD (3 Days at 27°C)	90.0	-	20.0	30	20.841
5	Ni	BLQ (LOQ-0.002)	3	BLQ (LOQ-0.002)	3	-
6	Cu	BLQ (LOQ-0.01)	3	BLQ (LOQ-0.01)	3	-
7	Zn	BLQ (LOQ-0.002)	15	BLQ (LOQ-0.002)	5	-
8	Cr (Total)	BLQ (LOQ-0.002)	2	BLQ (LOQ-0.002)	2	-
9	Pb	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.1	-
10	Cl	680.0	-	415.0	1000	-
11	SO <sub>4</sub>	1020.0	-	610.0	1000	-
12	Cd	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.05	-
13	Oil & Grease	30.6	20	BDL (DL-4.0)	10	-
14	TDS	1574.0	-	1490.0	2100	-
15	Ammonical Nitrogen as N	125.0	50	26.0	50	-
16	Fluoride	3.6	15	0.5	2	-
17	Sulphide	5.2	-	BDL (DL-1.0)	2.0	-

All values are in mg/l except pH

pH (at Site), TDS (at Site)

Flow : 2.7 MLD

  
 Dr. NANDITA MOITRA  
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
Okhla (24 MLD)  
01/06/2020

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	-	5.5-9.0	-	5.5-9.0	-
2	TSS	-	250	-	100	-
3	COD	-	-	-	250	-
4	BOD (3 Days at 27°C)	-	-	-	30	-
5	Ni	-	3	-	3	-
6	Cu	-	3	-	3	-
7	Zn	-	15	-	5	-
8	Cr (Total)	-	2	-	2	-
9	Pb	-	1	-	0.1	-
10	Cl	-	-	-	1000	-
11	SO <sub>4</sub>	-	-	-	1000	-
12	Cd	-	1	-	0.05	-
13	Oil & Grease	-	20	-	10	-
14	TDS	-	-	-	2100	-
15	Ammonical Nitrogen as N	-	50	-	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	-	-	-	2.0	-

All values are in mg/l except pH  
pH (at Site), TDS (at Site)

Remarks: Water was not available.

*Maitra*  
Dr. NANDITA MOITRA  
Scientist 'C'

AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
 Badli (12 MGD)  
 18/05/2020  
 14:30 to 14:40  
 Mr. Navneet Srivastava  
 5 Ltr. (Each)

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.42	5.5-9.0	8.51	5.5-9.0	9.21
2	TSS	120.0	250	20.2	100	27.9
3	COD	320.0	-	100.0	250	59.1
4	BOD (3 Days at 27°C)	110.0	-	28.0	30	15.8
5	Ni	0.3406	3	0.0542	3	-
6	Cu	BLQ (LOQ-0.01)	3	BLQ (LOQ-0.01)	3	-
7	Zn	0.0516	15	BLQ (LOQ-0.002)	5	-
8	Cr (Total)	BLQ (LOQ-0.002)	2	BLQ (LOQ-0.002)	2	-
9	Pb	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.1	-
10	Cl	80.0	-	96.0	1000	-
11	SO <sub>4</sub>	142.0	-	120.0	1000	-
12	Cd	BLQ (LOQ-0.002)	1	BLQ (LOQ-0.002)	0.05	-
13	Oil & Grease	24.2	20	4.8	10	-
14	TDS	788.0	-	57.5	2100	-
15	Ammonical Nitrogen as N	218.0	50	20.2	50	-
16	Fluoride	2.2	15	0.2	2	-
17	Sulphide	2.0	-	BDL (DL-1.0)	2.0	-

All values are in mg/l except pH  
 pH (at Site), TDS (at Site)  
 Flow : 2.01 MLD

*Nandita*  
 Dr. NANDITA MOITRA  
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

- 1 Name & Address of Ind./Unit
- 2 Name of CETP Plant
- 3 Date of Sampling
- 4 Time of Sampling
- 5 Sampling Done by
- 6 Sample Quantity

Delhi Pollution Control Committee  
Nangloi (12 MLD)  
16/05/2020

S. No.	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	-	5.5-9.0	-	5.5-9.0	-
2	TSS	-	250	-	100	-
3	COD	-	-	-	250	-
4	BOD (3 Days at 27°C)	-	-	-	30	-
5	Ni	-	3	-	3	-
6	Cu	-	3	-	3	-
7	Zn	-	15	-	5	-
8	Cr (Total)	-	2	-	2	-
9	Pb	-	1	-	0.1	-
10	Cl	-	-	-	1000	-
11	SO <sub>4</sub>	-	-	-	1000	-
12	Cd	-	1	-	0.05	-
13	Oil & Grease	-	20	-	10	-
14	TDS	-	-	-	2100	-
15	Ammonical Nitrogen as N	-	50	-	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	-	-	-	2.0	-

All values are in mg/l except pH  
pH (at Site), TDS (at Site)

Remarks: Refused to provide sample.

*N. Moitra*  
Dr. NANDITA MOITRA  
Scientist 'C'