



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD)

Report Number: DPCC/W/CETP/20-21/258 / 2858

Dated: 19/01/2021

1. Name & Address of Ind. / Unit
WAZIRPUR CETP (24 MLD)
2. Sampling location
Inlet and Outlet of CETP
3. Date of Sampling
10.12.2020
4. Sample analyzed and results
DPCC LAB
5. Parameters analyzed and result

S. No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	6.6	6-9	6.9	6-9	6.81	1.30 (I)
2	TSS	128	250	72	100	226.89	-215.12 (D)
3	COD	304	...	180	250	364.3	-102.38 (D)
4	BOD (3 days at 27° C)	76	...	40	30	116.7	-191.75 (D)
5	Ni	0.88	3	0.77	3	-	-
6	Cu	0.20	3	0.18	3	-	-
7	Zn	1.89	15	1.0	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	650	...	740	1000	-	-
11	SO ₄	826	...	491	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	16.0	20	4.0	10	-	-
14	TDS	1790	...	1620	2100	-	-
15	Ammonical Nitrogen as N	56.1	50	48.4	50	-	-
16	Sulphide	3	...	2.1	2.0	-	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Remarks: OLMS was not working.

Flow: 1.2 MLD


(I)-Increase & (D)-Decrease

Maitra

SR. SCIENTIST

Dr. NANDITA MOITRA

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF SMA CETP (12 MLD)

Report Number: DPCC/W/CETP/20-21/259/2859

Dated: 19/01/2021

1. Name & Address of Ind. / Unit SMA CETP (12 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 10.12.2020
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	6.7	6-9	7.3	6-9	7.72	-5.75 (D)
2	TSS	428	250	52	100	24.9	52.11 (I)
3	COD	664	...	152	250	68.61	54.86 (I)
4	BOD (3 days at 27° C)	200	...	28	30	18.92	32.42 (I)
5	Ni	2.13	3	0.91	3	-	-
6	Cu	2.17	3	0.20	3	-	-
7	Zn	2.28	15	1.75	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	1315	...	1235	1000	-	-
11	SO ₄	802	...	666	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	24.8	20	3.2	10	-	-
14	TDS	2610	...	2110	2100	-	-
15	Ammonical Nitrogen as N	50.2	50	11.1	50	-	-
16	Sulphide	3.6	...	1.1	2.0	-	-

All values are in mg/l except pH


No Standards

ND- Not Detectable

Flow: 1.90 MLD

(I)-Increase & (D)-Decrease

N. Moitra
SR. SCIENTIST
Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF OKHLA CETP (24 MLD)

Report Number: DPCC/W/CETP/20-21/260 / 2860

Dated: 19/01/2021

1. Name & Address of Ind. / Unit OKHLA CETP (24 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 08.12.2020
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	7.3	6-9	7.3	6-9	7.5	-2.73 (D)
2	TSS	784	250	44	100	42.64	3.09 (I)
3	COD	584	...	140	250	85.53	38.90 (I)
4	BOD (3 days at 27° C)	340	...	28	30	25.58	8.64 (I)
5	Ni	0.69	3	0.55	3	-	-
6	Cu	0.29	3	0.19	3	-	-
7	Zn	2.49	15	1.02	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	410	...	355	1000	-	-
11	SO ₄	334	...	323	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	36.0	20	3.6	10	-	-
14	TDS	1310	...	1190	2100	-	-
15	Ammonical Nitrogen as N	32.6	50	5.0	50	-	-
16	Sulphide	5.1	...	2.1	2.0	-	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow: 1.793 MLD

(I)-Increase & (D)-Decrease

N. Moitra
SR.SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NARELA CETP (24 MLD)

Report Number: DPCC/W/CETP/20-21/261/2861

Dated: 19/01/2021

1. Name & Address of Ind. / Unit NARELA CETP (22.5 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 07.12.2020
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	7.0	6-9	7.1	6-9	-	-
2	TSS	424	250	62	100	-	-
3	COD	632	...	156	250	-	-
4	BOD (3 days at 27° C)	240	...	30	30	-	-
5	Ni	1.14	3	0.51	3	-	-
6	Cu	0.19	3	0.15	3	-	-
7	Zn	1.02	15	0.86	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	1190	...	1110	1000	-	-
11	SO ₄	763	...	516	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	28.4	20	3.2	10	-	-
14	TDS	2970	...	2270	2100	-	-
15	Ammonical Nitrogen as N	10.87	50	5.0	50	-	-
16	Sulphide	6.0	...	5.8	2.0	-	-

All values are in mg/l except pH

... No Standards


ND- Not Detectable

Flow: 22.5 MLD

Remarks: Refused for calibration

N. Mitra
SR.SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NARAYANA CETP (21.6 MLD)

Report Number: DPCC/W/CETP/20-21/262 | 2862

Dated: 19/01/2021

1. Name & Address of Ind. / Unit NARAYANA CETP (21.6 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 02.12.2020
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result:

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	6.8	6-9	7.0	6-9	7.26	-3.71 (D)
2	TSS	200	250	36	100	30.3	15.83 (I)
3	COD	320	...	80	250	51.0	36.25 (I)
4	BOD (3 days at 27° C)	120	...	20	30	10.7	46.5 (I)
5	Ni	0.58	3	0.03	3	-	-
6	Cu	0.23	3	0.20	3	-	-
7	Zn	0.88	15	0.60	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	510	...	485	1000	-	-
11	SO ₄	483	...	201	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	16.0	20	2.0	10	-	-
14	TDS	950	...	760	2100	-	-
15	Ammonical Nitrogen as N	27.0	50	10.89	50	-	-
16	Sulphide	6.8	...	6.2	2.0	-	-

All values are in mg/l except pH

... No Standards


ND- Not Detectable

Flow: 4.68 MLD

(I)-Increase & (D)-Decrease

N Mehta
SR.SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NANGLOI CETP (12 MLD)

Report Number: DPCC/W/CETP/20-21/263/2863

Dated: 19/01/2021

- Name & Address of Ind. / Unit NANGLOI CETP (12 MLD)
- Sampling location Inlet and Outlet of CETP
- Date of Sampling 03.12.2020
- Sample analyzed and results DPCC LAB
- Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	7.4	6-9	6.9	6-9	-	-
2	TSS	736	250	38	100	-	-
3	COD	784	...	96	250	-	-
4	BOD (3 days at 27° C)	350	...	22	30	-	-
5	Ni	0.29	3	0.21	3	-	-
6	Cu	0.19	3	0.18	3	-	-
7	Zn	2.17	15	1.75	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	2345	...	1875	1000	-	-
11	SO ₄	466	...	385	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	28.0	20	1.6	10	-	-
14	TDS	3040	...	2690	2100	-	-
15	Ammonical Nitrogen as N	68.0	50	29.1	50	-	-
16	Sulphide	6.9	...	6.8	2.0	-	-

All values are in mg/l except pH


... No Standards

ND- Not Detectable

FLOW 3.34 MLD

Remarks: OLMS was not working due to maintenance of pipeline

N. Moitra
SR.SCIENTIST
Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD)

Report Number: DPCC/W/CETP/20-21/264/2864

Dated: 19/01/2021

1. Name & Address of Ind. / Unit MANGOLPURI CETP (2.4 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 03.12.2020
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	7.3	6-9	7.3	6-9	7.35	-0.68 (D)
2	TSS	160	250	66	100	58.2	11.81 (I)
3	COD	364	...	188	250	133.7	28.88 (I)
4	BOD (3 days at 27° C)	96	...	38	30	42.5	-11.84 (D)
5	Ni	0.43	3	0.29	3	-	-
6	Cu	0.20	3	0.19	3	-	-
7	Zn	0.79	15	0.74	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	2230	...	2000	1000	-	-
11	SO ₄	466	...	285	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	12.4	20	4.8	10	-	-
14	TDS	3040	...	2940	2100	-	-
15	Ammonical Nitrogen as N	47.0	50	10.86	50	-	-
16	Sulphide	6.3	...	1.7	2.0	-	-

All values are in mg/l except pH

... No Standards


ND- Not Detectable

Flow : 0.81 MLD

(I)-Increase & (D)-Decrease

Mehta
SR.SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD)

Report Number: DPCC/W/CETP/20-21/265/2865

Dated: 19/01/2021

1. Name & Address of Ind. / Unit LAWRENCE ROAD (12 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 10.12.2020
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	7.1	6-9	7.2	6-9	7.55	-4.86 (D)
2	TSS	348	250	82	100	38.5	53.04 (I)
3	COD	496	...	120	250	112.7	6.08 (I)
4	BOD (3 days at 27° C)	155	...	48	30	36.4	24.16 (I)
5	Ni	0.32	3	0.29	3	-	-
6	Cu	0.19	3	0.18	3	-	-
7	Zn	1.18	15	1.09	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	1345	...	1325	1000	-	-
11	SO ₄	1128	...	671	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	20.4	20	7.2	10	-	-
14	TDS	2270	...	1970	2100	-	-
15	Ammonical Nitrogen as N	50.6	50	47.6	50	-	-
16	Sulphide	3.4	...	0.5	2.0	-	-

All values are in mg/l except pH


... No Standards

ND- Not Detectable

Flow : 2.045 MLD

(I)-Increase & (D)-Decrease

Nandita
SR.SCIENTIST
Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD)

Report Number: DPCC/W/CETP/20-21/266/2866

Dated: 19/01/2021

1. Name & Address of Ind. / Unit JHILMIL CETP (16.8 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 09.12.2020
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	7.1	6-9	7.4	6-9	7.09	4.189 (I)
2	TSS	428	250	52	100	47.2	9.23 (I)
3	COD	580	...	136	250	87.4	35.73 (I)
4	BOD (3 days at 27° C)	190	...	30	30	28.6	4.66 (I)
5	Ni	0.88	3	0.10	3	-	-
6	Cu	0.22	3	0.19	3	-	-
7	Zn	2.49	15	1.78	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	1125	...	970	1000	-	-
11	SO ₄	529	...	264	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	24.4	20	4.8	10	-	-
14	TDS	1780	...	1660	2100	-	-
15	Ammonical Nitrogen as N	29.9	50	19.2	50	-	-
16	Sulphide	6.2	...	3.1	2.0	-	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow : 2.945 MLD

(I)-Increase & (D)-Decrease

N. Mitra

SR.SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF BAWANA CETP (35 MLD)

Report Number: DPCC/W/CETP/20-21/267 / 2867 dated: 19/01/2021

1. Name & Address of Ind. / Unit BAWANA CETP (35 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 07.12.2020
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	6.9	6-9	6.7	6-9	7.6	-13.43 (D)
2	TSS	524	250	72	100	43.0	40.27 (I)
3	COD	744	...	108	250	65.2	39.62 (I)
4	BOD (3 days at 27° C)	280	...	28	30	13.0	53.57 (I)
5	Ni	2.39	3	0.03	3	-	-
6	Cu	0.35	3	0.19	3	-	-
7	Zn	6.03	15	1.62	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	2455	...	2245	1000	-	-
11	SO ₄	803	...	700	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	32.0	20	4.4	10	-	-
14	TDS	4010	...	3960	2100	-	-
15	Ammonical Nitrogen as N	62.0	50	16.0	50	-	-
16	Sulphide	7.8	...	6.0	2.0	-	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable


Flow: 18.62 MLD

(I)-Increase & (D)-Decrease

Nandita

SR.SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF BADLI CETP (12 MLD)

Report Number: DPCC/W/CETP/20-21/268 /2868

Dated: 19/01/2020

1. Name & Address of Ind. / Unit
BADLI CETP (12 MLD)
2. Sampling location
Inlet and Outlet of CETP
3. Date of Sampling
04.12.2020
4. Sample analyzed and results
DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	3.8	6-9	6.8	6-9	7.85	-15.44 (D)
2	TSS	140	250	108	100	63.1	41.57 (I)
3	COD	180	...	152	250	98.5	35.19 (I)
4	BOD (3 days at 27° C)	52	...	42	30	29.8	29.04 (I)
5	Ni	1.06	3	0.10	3	-	-
6	Cu	0.18	3	0.16	3	-	-
7	Zn	1.87	15	1.80	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	1175	...	235	1000	-	-
11	SO ₄	581	...	166	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	10.8	20	7.2	10	-	-
14	TDS	2030	...	990	2100	-	-
15	Ammonical Nitrogen as N	73	50	27	50	-	-
16	Sulphide	8.0	...	7.2	2.0	-	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable.

Flow - 1.385 MLD

(I)-Increase & (D)-Decrease

N. Mittra

SR.SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF GTK CETP (6 MLD)

Report Number: DPCC/W/CETP/20-21/269/2869 Dated: 19/01/2021

1. Name & Address of Ind. / Unit
GTK CETP (6 MLD)
2. Sampling location
Inlet and Outlet of CETP
3. Date of Sampling
10.12.2020
4. Sample analyzed and results
DPCC LAB
5. Parameters analyzed and result

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	7.0	6-9	7.3	6-9	7.64	-4.65 (D)
2	TSS	288	250	56	100	75.95	-35.62 (D)
3	COD	360	...	128	250	116.10	9.29 (I)
4	BOD (3 days at 27° C)	195	...	30	30	30.02	-0.06 (D)
5	Ni	0.40	3	ND	3	-	-
6	Cu	0.25	3	0.16	3	-	-
7	Zn	0.90	15	0.79	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	870	...	620	1000	-	-
11	SO ₄	820	...	712	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	28.0	20	3.2	10	-	-
14	TDS	2010	...	1810	2100	-	-
15	Ammonical Nitrogen as N	87.4	50	41.2	50	-	-
16	Sulphide	3.6	...	2.7	2.0	-	-

All values are in mg/l except Ph

... No Standards


ND- Not Detectable

Flow: 1.05 MLD

(I)-Increase & (D)-Decrease

N. Moitra
SR.SCIENTIST

DR. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE
4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF MAYAPURI CETP (12 MLD)

Report Number: DPCC/W/CETP/20-21/270 | 2870

dated: 19/01/2021

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MAYAPURI CETP (12 MLD)
Inlet and Outlet of CETP
02.12.2020
DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS	% Variation
		Water Quality	EPA Standards	Water Quality	EPA Standards		
1	pH	7.2	6-9	7.5	6-9	7.53	-0.4 (D)
2	TSS	180	250	30	100	31.5	-5 (D)
3	COD	360	...	84	250	72.6	13.57 (I)
4	BOD (3 days at 27° C)	95	...	18	30	22.2	-23.33 (D)
5	Ni	0.29	3	0.10	3	-	-
6	Cu	0.25	3	0.18	3	-	-
7	Zn	0.65	15	0.47	5	-	-
8	Cr (Total)	ND	2	ND	2	-	-
9	Pb	ND	1	ND	0.1	-	-
10	Cl	865	...	745	1000	-	-
11	SO ₄	814	...	392	1000	-	-
12	Cd	ND	1	ND	0.05	-	-
13	Oil & Grease	12.0	20	1.2	10	-	-
14	TDS	1730	...	1530	2100	-	-
15	Ammonical Nitrogen as N	45.0	50	18.0	50	-	-
16	Sulphide	6.1	...	3	2.0	-	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow: 2.66 MLD

(I)-Increase & (D)-Decrease

N. Mitra

SR.SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'